

# *Modelling electricity storage applications: The UK case*



Mary Black, Goran Strbac, Jay Mariyappan  
*GreenNet* – Final International Dissemination  
Conference

Vienna, 14 December, 2004

# Agenda

- Scope of GreenNet Workpackage 3
- Background to the modelling study & objectives
- Approach to evaluation of the value of storage
- Summary of key results
- Implementation of results in *GreenNet*

# Scope: Cost & Technical Opportunities for Storage



- Assessment of current status of storage technology options
- Applications of each technology option & an evaluation of market opportunities
- Development of a formal methodology for evaluation of storage
- UK case study: value of storage in balancing the system with increasing intermittent generation



# Background


- Increasing intermittent renewables (e.g. wind) may displace electricity from large thermal generation plant (e.g. CCGTs)
- Intermittent generation less predictable (uncertainty rises above the normal level of uncertainty in balancing supply & demand) leading to increasing reserve requirements (additional balancing costs?)
- Locational (transmission) impacts

# Role for Storage & DSM?




- **Increased penetration of RES-E**  
store power when in excess for later use
- **Increased value of energy**  
higher buy-back rates for predictable energy sources

# Current Storage Technologies: Pumped Storage



# Emerging Storage Options



e.g. Hunterston  
Hydrogen Ltd  
(UK): 100MW  
wind &  
hydrogen  
“balancing”  
scheme



# Demand Side Management (DSM)

- Devices (e.g. water heaters) controlled to switch off at certain times (i.e. when intermittent generation output is low & shortage of supply) to lower demand
- Time-shifting consumption demand i.e. smoothing or “virtual storage”
- Variety of approaches (options evaluated in more detail WP5)



# Objectives of the study

- To provide estimates of the *value* of storage and DSM in the balancing system with increasing penetration of intermittent generation in the context of the UK system

# Approach

- At its core: Economic Dispatch of generation in system with conventional generation, wind, storage and DSM. Linear programming optimisation minimises fuel costs
- Hourly dispatch over 1 year, simulated using software model of power system
- Compare fuel costs in simulations with and without storage/DSM. Assess benefit of any savings

# Assumptions

- Cost based approach (market arrangements not considered)
- Balancing task performed at system level not at individual generation/supply company level
- Arbitrage excluded
- Reliability & capacity performance equal to other plant
- Management of network constraints not considered
- Generic, flexible bulk storage technology

# Economic Dispatch

- Optimal dispatch of conventional generation, storage & DSM



Final International Dissemination Conference, Vienna – 14 December, 2004



# Economic Dispatch

- Optimal dispatch: generation levels & use of storage/DSM

StorageWindDemandModel - [StorageWindDema1:2]


File Edit View Window Help

period	date	D-W Diff	load	wind	charged	discharged	effic loss	loadshed	windshed	dsm	gen 1	gen 2	gen 3	gen 4	gen 5
241	11 Jun: 00:00	0.000	23482.500	2115.224	-232.724	0.000	-46.545	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
242	11 Jun: 01:00	0.000	22305.000	2184.076	-479.076	0.000	-95.815	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
243	11 Jun: 02:00	0.000	21847.500	2153.868	-406.368	0.000	-81.274	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
244	11 Jun: 03:00	0.000	21067.500	2130.704	-663.204	0.000	-132.641	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
245	11 Jun: 04:00	0.000	20857.500	2164.376	-906.876	0.000	-181.375	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
246	11 Jun: 05:00	0.000	20895.000	2306.280	-1011.280	0.000	-202.256	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
247	11 Jun: 06:00	0.000	24390.000	2437.768	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
248	11 Jun: 07:00	0.000	31965.000	2612.592	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
249	11 Jun: 08:00	0.000	37770.000	2753.228	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
250	11 Jun: 09:00	0.000	40395.000	2831.156	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
251	11 Jun: 10:00	0.000	41085.000	2818.440	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
252	11 Jun: 11:00	0.000	41527.500	2805.796	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
253	11 Jun: 12:00	0.000	41782.500	2826.276	0.000	615.462	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
254	11 Jun: 13:00	0.000	40890.000	2811.700	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
255	11 Jun: 14:00	0.000	40335.000	2696.500	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
256	11 Jun: 15:00	0.000	39615.000	2560.552	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
257	11 Jun: 16:00	0.000	40185.000	2452.668	0.000	2000.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
258	11 Jun: 17:00	0.000	40357.500	2292.560	0.000	0.000	0.000	0.000	0.000	-28.235	220.000	220.000	220.000	220.000	220.000
259	11 Jun: 18:00	0.000	37785.000	2145.880	0.000	0.000	0.000	0.000	0.000	-28.235	220.000	220.000	220.000	220.000	220.000
260	11 Jun: 19:00	0.000	35475.000	2183.352	0.000	0.000	0.000	0.000	0.000	42.352	220.000	220.000	220.000	220.000	220.000
261	11 Jun: 20:00	0.000	34005.000	2246.528	0.000	0.000	0.000	0.000	0.000	14.117	220.000	220.000	220.000	220.000	220.000
262	11 Jun: 21:00	0.000	34650.000	2281.800	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
263	11 Jun: 22:00	0.000	33712.500	2268.340	0.000	344.160	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000
264	11 Jun: 23:00	0.000	28807.500	2219.640	0.000	0.000	0.000	0.000	0.000	0.000	220.000	220.000	220.000	220.000	220.000

For Help, press F1

# Wind and Demand

- Generic UK wind and demand profiles used




Above is an example of profiles with 30GW of wind

Final International Dissemination Conference, Vienna – 14 December, 2004


# DSM: Demand Change Profiles

- Demand change profile for a device: a control period during which it is switched off and reduces demand, and a payback period when it is switched back on thus increasing demand.
- Way that energy is restored is dependent on the amount of energy shifted. Change profiles modelled outside our system



# DSM: Candidate Control Schemes

- DSM control schemes define the time of day that devices can be switched off, and for how long a period






# Modelling Reserve


- Unit commitment is carried out using a “forecast” net “demand minus wind” profile, and economic dispatch is carried out using the “actual” profile
- The forecast profile is based on randomized additions/subtractions to the actual profile generated from a normal distribution in which the standard deviation is calculated in the same way as with reserve

# Reserve: Imbalances distribution



- Shortages occur at imbalances  $> 1690$  MW when synchronised reserve is scheduled at 2 standard deviations


# Storage used for reserve




- 2 GW storage provides standing reserve for imbalances between forecast and actual net demand – wind profiles Results here are for 30 GW wind with standing reserve required to cover imbalances  $> 2$  standard deviations
- Optimal dispatch automatically calculates storage use.

# Utilisation of surplus wind

hourly windshed and loadshed from 1st June to 30th June  
surplus wind shed without use of storage



wind and storage operation from 1st June to 30th June  
storage utilises surplus wind




- Windshed occurs in June when wind at 30 GW. Optimal economic dispatch automatically calculates how storage can utilise surplus wind, remove wind shed, and discharge stored energy later to save fuel.

Final International Dissemination Conference, Vienna – 14 December, 2004



# Main inputs window



storage size (GWh)  
20

storage power rating (GW)  
2

storage efficiency (%)  
0.8

initial storage level (%)  
0

wind size (GW)  
30

Read scenario Write scenario

default generation  
 ccgt  
 mixed

Reserve  
forecast error   
std dev 2

chart display period  
October

shortage range  
200 to 400 MW

Dispatch generators

### Conventional Generation

id	type	max capacity (MW)	min stable gen (MW)
ccgt 0	ccgt	650.000	500.000
ccgt 1	ccgt	650.000	500.000
ccgt 2	ccgt	650.000	500.000
ccgt 3	ccgt	650.000	500.000

add generator delete amend Commit generators

### Demand Side Management

scheme id	description	hr 0 (MW)	hr 1 (MW)
cs1	off at midn...	-0.475	-0.375
cs2	off at 1, o...	0.000	-0.375
cs3	off at 2, o...	0.000	0.000
cs4	off at 3, o...	0.000	0.000

add scheme delete amend max num devices 0


- Alter parameters to run many case studies

Final International Dissemination Conference, Vienna – 14 December, 2004

# Storage case study parameters


peak demand (GW)	max wind (GW)	Storage rating (GW)	Storage size (GWh)	Storage efficiency
56.79	20	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	26	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	30	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	36	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	40	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	46	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	50	0, 2, 6, 10, 16, 20	rating * 10 hours	80%
56.79	56	0, 2, 6, 10, 16, 20	rating * 10 hours	80%

# Results: Windshed savings - storage



- storage beneficial for wind > 20 GW
- marginal benefits of additional storage capacity get smaller

# Fuel savings - storage




N.B. efficiency losses when charging reduce fuel savings



# DSM case study parameters

Peak demand (GW)	Max wind (GW)	DSM number of devices	Hourly control period load reduction (GW)
56.79	20	0, 200, 600, 1000, 1600, 2000	2, 6, 10, 16, 20
56.79	26	0, 200, 600, 1000, 1600, 2000	2, 6, 10, 16, 20
56.79	30	0, 200, 600, 1000, 1600, 2000	2, 6, 10, 16, 20
56.79	36	0, 200, 600, 1000, 1600, 2000	2, 6, 10, 16, 20
56.79	40	0, 200, 600, 1000, 1600, 2000	2, 6, 10, 16, 20
56.79	46	0, 200, 600, 1000, 1600, 2000	2, 6, 10, 16, 20

# Wind shed savings - DSM



Considerably less than storage!

# Fuel savings - DSM

- Some fuel savings but much less than storage e.g. for 30 GW wind, savings of 56GWh, whilst for storage (80% efficiency)  $\sim$  200GWh

# Why low DSM potential?

- Limitations in deployment of DSM
  - Payback of energy lost during the control period (how demand is restored to devices)
  - Timing issues (i.e. for use of surplus wind DSM devices must already be switched off)




# Opportunities for Balancing

## ■ Case study parameters


Storage Rating (standing reserve)	Storage efficiency	Storage energy	Wind penetration	Generation mixes
None	-		20, 25, 30 %	LF, MF, HF
2 GW	70%	40 GWh	20, 25, 30 %	LF, MF, HF
3 GW	70%	60 GWh	20, 25, 30 %	LF, MF, HF
4 GW	70%	80 GWh	20, 25, 30 %	LF, MF, HF
5 GW	70%	100 GWh	20, 25, 30 %	LF, MF, HF

# Balancing costs for 20% wind penetration




- Balancing costs greatest for LF system
- Costs begin to increase again for large amounts (5 MW of storage) due to not enough wind for storage!

# Balancing costs for 25% wind penetration)



- Balancing cost reduction greatest for LF system
- Value of storage increases with size

# CO<sub>2</sub> reductions



- Increasing storage size increases CO<sub>2</sub> reductions & as flexibility decreases



# Integration of Results into *GreenNet*

- Value of storage in terms of balancing costs
- UK results relevant for European grid as role of storage for providing standing reserve based on forecast uncertainty NOT demand (however SD of wind will be different – more predictable in Europe)

**System operation**

Select:

 **Germany**  
**Wind onshore**

without storage/load management |  with storage/load management

**System operation costs**

*System capacity costs*

High scenario  Yes  No

with capacity credit  €/MWh


without capacity credit  €/MWh

*Balancing costs*


High scenario  Yes  No

Value  €/MWh


storage balancing costs 5% wind




storage balancing costs 10% wind



storage balancing costs 20% wind



storage balancing costs 30% wind



# Conclusions

- Opportunities for storage in providing standing reserve seem promising (particularly for high wind penetrations)
- Storage used for reserve at lower wind penetration levels than in utilising surplus wind
- Storage results more promising than DSM results
- The use of storage & DSM due solely to the introduction of wind into the system
- Further study & refinement? EU 25 (European grid data, different storage technology cases, PV, wave, tidal penetration etc.)